



<b>Type</b>	TFEA
<b>Product group</b>	Particulate filter air diffuser
<b>Manufacturer</b>	TROX SE Heinrich-Trox-Platz • 47506 Neukirchen-Vluyn • Germany E-Mail trox-de@troxgroup.com • Internet www.trox.de

### Manufacturer's declaration in accordance with VDI guideline 6022

EN 16798-3:2017-11	Energy performance of buildings - Ventilation for buildings - Part 3: For non-residential buildings - Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4)
DIN 1946-4:2018-09	Ventilation and air conditioning - Part 4: Ventilation in buildings and rooms of health care
ÖNORM H 6020:2019 06	Ventilation and air conditioning plants for locations for medical use - Design, construction, operation, maintenance, technical and hygienic inspections
ÖNORM H 6021:2023-01	Ventilation and air conditioning plants - Specifications keeping them clean and cleaning - National supplement to ÖNORM EN 15780
SWKI VA104-01:2019	Ventilation and air conditioning - Air quality - Part 1: Hygiene requirements for ventilation and air conditioning systems and units
SWKI VA105-01:2015	Ventilation and air conditioning systems in rooms used for medical purposes (planning, realisation, qualification, operation)



### Summary of the test result

For the purpose of this declaration of conformity a sample of each product type mentioned above was tested at the factory, and related data sheets, technical documentation and test reports were appraised.

The test of the above mentioned samples and the appraisal of the provided documents have shown that the hygiene requirements stipulated in the above mentioned standards and guidelines are met. This is to confirm that the products meet the hygiene requirements stipulated in the specified standards and guidelines.

Neukirchen-Vluyn, 19.03.2026

Pascal Pollmann

Frank Eltze  
Head of IMS (Integrated Management Systems)